

2 Williams Street
Chelsea, MA 02150
(617) 889 - 6515



QUALITY CERTIFICATE

Vessel	Sample & Analysis	Port	Providence, R.I.	Report	024506
Customer	Sprague Providence	Date	February 26, 2006	Reference	
Operation	Analysis	Terminal	Sprague Providence	Sample #	539798

Name of material being tested
Description of sample source
Samples Drawn by (company)
Samples Tested by (company)

No 6 Fuel Oil

Shore Tank # 6 After Discharge
Inspectorate
Inspectorate

Tests being Performed	Test method	Sample Results		
Gravity API @ 60F / Denisty	D - 4052	11.5	/	0.9892
Flash Point, PMCC, F	D - 93		195	
Viscosity cSt @ 122F	D - 445		280.3	
Viscosity SSF @ 122F	D - 2161		132.3	
Pour Point C / F	D - 97		-3 / 27	
Sulfur , Wt%	D - 4294		0.958	
Water and Sediment, Vol %	D - 1796		0.020	
Sediment by Extraction, wt%	D - 473		0.15	
Water by Distillation, Vol%	D - 95		0.1	
Gross Heat of Combustion, BTU / lb	D - 240		18,425	
Gross Heat of Combustion, BTU / gal	D - 240		151,837	
Ash, wt %	D - 482		0.040	
Vanadium, ppm	D - 5863B		90	
Sodium, ppm	D - 5863A		78	
Nitrogen, wt%	D - 5762		0.4997	
Ashphaltenes, wt%	IP - 143		5.20	
Conradson Carbon Residue	D - 189		12.8	
<p>SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.</p>				

** Annotates Analysis Contracted Out

*** Annotates Loadport information- this test was not performed by Inspectorate